



ACTIVE FIRE PROTECTION-EQUIPMENT LISTING SCHEME

Commonwealth Scientific and Industrial Research Organisation, Australia
Ph.: 61 3 9252 6000 Fax: 61 3 9252 6011
Web site: <http://www.ActivFire.gov.au> E-mail: info@ActivFire.gov.au

LISTING NUMBER

afp - 1329

Dates: Registration: 15-May-2000 Page 1 of 2
Version: ..1.5... 31-Jul-2006
Valid until†: 31-Jul-2007

PRODUCT LISTING DATA SHEET **(Active Fire Protection Equipment)**

Product designation

Tyco, Model SU0601, manual call point

(Refer to the Technical Specification section of this document for further specific detail)

Supplier

Tyco Fire & Security

47 Gilby Road, MOUNT WAVERLEY, VIC, AUSTRALIA, 3149

Manufacturer

KAC Alarm Company Limited

15-19 Trescott Road, Trafford Park, SMALLWOOD REDDITCH, WORCESTERSHIRE, UNITED KINGDOM, B98 7AH

Supplier's description

The Tyco, Model SU0601, manual call point is a red, indoor, surface mounted, break glass manual call point with normally open, closing on contact alarm contacts.

The red plastic mounting box has a tear-off template for locating cable entry holes.

Conformance criteria and evaluation

The Tyco, Model SU0601, manual call point complies with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.5-1996, 'Automatic fire detection and alarm systems - Manual call points (all requirements other than weathering)' including Amdt 1 (August 1998).

Listing is subject to ActivFire Scheme terms and conditions as applicable to the designated registrant and supplier.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this Product Listing Data Sheet, are derived from qualifications within the report of the testing agency and/or other related technical documentation. It is recommended that all details with respect to design, assembly and installation restrictions should be checked against the designated supplier's/maker's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

The Tyco, Model SU0601, manual call point met the requirements of Australian Standard AS 1603:Part 5 - 1996, including Amendment No. 1 (all requirements except weathering), when used in conjunction with compatible control and indicating equipment and mounted in an indoor and dry environment.



This product listing data sheet should be read in conjunction with the general requirements of the terms and conditions of listing under the ActivFire Scheme.

© CSIRO Australia, 2006

Executive Officer

Technical specification

The following details are a representative extract of the technical specification for the Tyco, Model SU0601, manual call point and may be subject to change. Complete and current details should be determined from the designated supplier's/manufacturer's technical manual/data sheets.

Maximum working voltage:	30 Vdc 50 Vac 45/60 Hz
Maximum current rating:	3A
Material:	Polycarbonate ABS blend Self-extinguishing V-0 to UL 94
Dimensions:	87w x 87h x 52d (on a surface mount box)

Supplementary information

Nil supplementary information.